



1. THE DEPTH LENGTH DIMENSIONS SHOWN ARE FOR STANDARD 1000 GAL. PRE CAST TANK. THE EXACT SIZE AND TYPE AND LOCATION OF EACH INTERCEPTOR SHALL BE APPROVED BY SPARTANBURG SANITARY SEWER DISTRICT.
2. CLEANING SHALL BE PERFORMED AS NECESSARY TO ASSURE PROPER FUNCTIONING OF THE GREASE TRAP INTERCEPTOR. WASTE MATERIAL REMOVED FROM GREASE TRAP SHALL BE DISPOSED OF PROPERLY: I.E.: NOT INTO SANITARY SEWER OR STREETS.
3. ALL PIPING SHALL BE DUCTILE IRON, SDR*35 PVC, OR SCHEDULE 40 PVC.
4. USE NON-SHRINK GROUT.
5. USE BUTYL RUBBER ROPE TO SEAL BETWEEN TANK SECTIONS.
6. LOCATE RISER UNDER MANHOLE COVER TO ENABLE VISUAL INSPECTION OF RISER PIPE.

REFERENCES _____



SINGLE CHAMBER
GREASE TRAP

NO.	BY	DATE	REVISION
1	RK	4/24/10	Changed Cast Iron to Ductile Iron

ENGINEERING DEPARTMENT

JOB NO.	DR. BY
FILE NO.	CHK. BY
DATE:	SHEET
SCALE: NTS	1 OF 1