



NOTES :

1. SHOP DRAWINGS SHALL BE SUBMITTED FOR ENCLOSURE SYSTEM FOR SWS REVIEW & APPROVAL PRIOR TO INSTALLATION.
2. ALL DIMENSIONS ARE APPROXIMATE IN INCHES.
3. [E] INDICATES THE ELECTRICAL RECEPTACLE. IT SHALL BE MOUNTED A MINIMUM OF 30" ABOVE THE SLAB. "E" INDICATES THE ELECTRICAL CONDUIT.
4. HEAT SHALL BE PROVIDED TO PREVENT FREEZING.
5. ALL FITTINGS IN BOX TO BE FLANGED, DUCTILE IRON, AND SHALL COMPLY WITH AWWA STANDARDS & SWS SPECIFICATIONS.
6. THRUST RESTRAINT BLOCKS SHALL COMPLY WITH SWS SPECIFICATIONS.
7. ELECTRICAL DESIGN PROVIDED BY OTHERS.
8. BACKFLOW ASSEMBLY SHALL BE APPROVED BY SWS. DOUBLE DETECTOR CHECK METERS TO BE USED, METER TO REGISTER IN GALLONS.
9. FOR RPZ INSTALLATIONS, (2) DRAIN HOLES MUST BE PROVIDED ABOVE GROUND WITH OPENINGS LARGE ENOUGH TO ACCOMMODATE THE FULL DISCHARGE OF THE RELIEF VALVE.



**ABOVE GROUND
FIRE SERVICE
ENCLOSURE**

SCALE: NONE REVISION DATE: JULY 6, 2009