

## GENERAL NOTES

1. LAY MAINS WITH MINIMUM 4' COVER.
2. UTILITIES WERE NOT LOCATED. CONTRACTOR RESPONSIBLE FOR ANY AND ALL UTILITY LOCATES.
3. ANY TRENCHES WHICH REQUIRE ENTRY BY S.W.S. PERSONNEL, MUST BE IN ACCORDANCE WITH ALL O.S.H.A. TRENCH SAFETY STANDARDS.
4. MAINTAIN MINIMUM 6" VERTICAL SEPARATION WHEN CROSSING OTHER UTILITIES, STORM DRAINS ETC. 18" VERTICAL OR 10' HORIZONTAL WHEN CROSSING SANITARY SEWERS.
5. ALL AIR RELIEF TAPS TO BE FIELD LOCATED BY S.W.S. INSPECTOR.
6. HORIZONTAL AND VERTICAL BENDS ARE TO BE USED AS DETERMINED BY S.W.S. INSPECTOR.
7. THE LAST JOINT OF PIPE ON EACH EXTENSION SHALL BE DUCTILE IRON PIPE IN ACCORDANCE WITH A.W.W.A. C151-91 WITH A WELDED-ON THRUST COLLAR AS INDICATED BY THE CONCRETE COLLAR DETAIL.
8. ANY CONCRETE VALVE MARKERS DEEMED NECESSARY BY THE INSPECTOR MUST BE FURNISHED AND SET BY THE CONTRACTOR.
9. THE CONTRACTOR IS RESPONSIBLE FOR MAKING ALL TAPS INCLUDING THE MAIN LINE TAP.
10. ALL HORIZONTAL AND VERTICAL BENDS, TEES, TAPS, ETC. ARE TO HAVE THRUST BLOCKING OR AN APPROVED RESTRAINT MECHANISM.
11. EXISTING VALVES TO BE OPERATED BY SWS PERSONNEL ONLY.
11. WATER LINE TO BE INSTALLED A MINIMUM OF 3' OFF EDGE PAVEMENT UNLESS APPROVED BY SWS
12. FIRE HYDRANTS TO BE FIELD LOCATED WITH SW FIELD INSPECTOR ASSISTANCE.



### *GENERAL NOTES*

SCALE: NONE

REVISION DATE: JULY 6, 2009