


# CONSTRUCTION DETAIL NO. 6



*NOTE:*

*INSTALLATIONS OF THE TYPE SHOWN ABOVE  
MUST BE DESIGNED BY A LICENSED ENGINEER AND MUST  
INCLUDE CONSIDERATION FOR THE FOLLOWING CONDITIONS:*

- SOIL TYPE*
- PIPE SIZE AND TYPE*
- EXCAVATION DEPTH*
- TEST PRESSURE*
- OPERATING PRESSURE*

*THE DESIGN MUST BE SUBMITTED TO THE SPARTANBURG  
WATER ENGINEERING DEPT FOR APPROVAL.*



*DIP TO HDPE  
TRANSITION*

SCALE: NONE

REVISION DATE: APRIL 13, 2009