



- SECTION
1. THE INVERT OF THE INLET PIPE SHALL NOT BE LESS THAN 2" ABOVE THE INVERT OF THE OUTLET PIPE.
 2. BAFFLE WALL SHALL BE LOCATED 2/3 DISTANCE FROM INLET SIDE, FOR GREASE ACCUMULATION, AND 1/3 DISTANCE FROM OUTLET SIDE.
 3. THE DEPTH AND LENGTH DIMENSIONS SHOWN ARE FOR STANDARD 1500 GAL. PRE CAST TANK. THE EXACT SIZE AND TYPE AND LOCATION OF EACH INTERCEPTOR SHALL BE APPROVED BY SPARTANBURG SANITARY SEWER DISTRICT.
 4. CLEANING SHALL BE PERFORMED AS NECESSARY TO ASSURE PROPER FUNCTIONING OF THE GREASE TRAP. WASTE MATERIAL REMOVED FROM GREASE TRAP SHALL BE DISPOSED OF PROPERLY: I.E.: NOT INTO SANITARY SEWER OR STREETS.
 5. ALL PIPING SHALL BE DUCTILE IRON, SDR*35 PVC, OR SCHEDULE 40 PVC.
 6. USE NON-SHRINK GROUT.
 7. USE BUTYL RUBBER ROPE TO SEAL BETWEEN TANK SECTIONS.
 8. LOCATE RISER UNDER MANHOLE COVER TO ENABLE VISUAL INSPECTION OF RISER PIPE.

REFERENCES _____



ENGINEERING DEPARTMENT

TWO CHAMBER
GREASE TRAP
1500 GALLON

JOB NO.

DR. BY

FILE NO.

CHK. BY

DATE:

SHEET

SCALE: NTS

1 OF 1

NO.	BY	DATE	REVISION
1	RK	4/24/10	Changed Cast Iron to Ductile Iron